



NOTES:

1. ALL CONCRETE SHALL BE 3600 PSI.
2. ALL JOINTS ARE TO BE SEALED WATER TIGHT.
3. WEIR IS TO BE POURED-IN-PLACE CONCRETE.
4. REFER TO NCDOT STANDARD DRAWINGS FOR BOX CONSTRUCTION.
5. NOT ACCEPTABLE FOR USE IN STREET RIGHT OF WAY WITHOUT CDOT/NCDOT APPROVAL.

NOT TO SCALE



CITY OF CHARLOTTE
LAND DEVELOPMENT STANDARDS
INCLUDES CHARLOTTE ETJ

FLOW SPLITTER STRUCTURE

BMP FIG. 4.1.11

STD. NO.	REV.
21.04	2